

# Ultra-Containment Berm Compact Model<sup>®</sup>

## SPECIFICATIONS (PVC)

### KEY FEATURES AND BENEFITS

- + Compact, lightweight, portable design - no inflation required.
- + Smaller sizes provide total containment of drums, tanks, generators, compressors and other equipment prone to leaks and spills.
- + Meets SPCC and EPA Container Storage Regulation 40 CFR 264.175.

### SIDEWALLS

- + Attached aluminum struts insert into sleeves along the sidewall.
- + Sidewalls must be put up or taken down manually when driving vehicle or equipment into Berm.

### COMPLIANCE

- + EPA 40 CFR 264.175 Containment of Containers Containing Free Liquid.
- + SPCC - Spill Prevention, Control and Countermeasure Act

Part#	Dimensions ft. (m)	Containment Capacity gal. (L)	Weight lbs. (kg)
8693	6 x 6 x 1 (1.8 x 1.8 x .3)	269 (1,018.28)	36 (16.3)
8694	10 x 10 x 1 (3 x 3 x .3)	749 (2,835.3)	68 (30.8)
8695	12 x 40 x 1 (3.7 x 12.2 x .3)	3,591 (13,593.4)	190 (86.2)
8696	14 x 54 x 1 (4.3 x 16.5 x .3)	5,655 (21,406.5)	270 (122.5)
8697	15 x 66 x 1 (4.6 x 20.1 x .3)	7,046 (26,672)	442 (200.5)





**ULTRATECH**  
INTERNATIONAL, INC.

#### PROCEDURE FOR BERM DEPLOYMENT:

STEP1: Select a level area and be sure that ground is swept clean of debris and sharp objects. The use of a ground cloth is recommended to prevent puncturing from underneath the Berm.

STEP2: Place the folded Berm at the setup location. Do not drag the folded berm. Unfold Berm and position as desired. Place each support strut into its associated sleeve in the Berm's sidewall. Continue this process until all struts are installed.

STEP3: If tread protectors are being used, place these in the unit at this time.

Your Berm is now ready for use.

#### Storage:

1. Sweep out Berm and be sure that it is dry and free of contaminants.
2. Store unit in clean, dry environment.

**Repair and Maintenance:** If a puncture or tear occurs, call for a Ratching Kit. Describe the damage to the service representative to ensure receipt of the proper kit.

#### PVC MATERIAL SPECS

	English	Metric	Testing Method
<b>Weight</b>	22 oz./yd <sup>2</sup>	745 g/m <sup>2</sup>	FS 5040 / ASTM D3776
<b>Width</b>	up to 126"	up to 320 cm	-
<b>Count</b>	18 x 16/1"	7 x 7/cm	-
<b>Denier</b>	1300 x 1500	1430 x 1650	-
<b>Grab Tensile</b>	459 x 418 lbs./1"	2042 x 1859 N/2.5 cm	FS 5100 / ASTM D5034
<b>Tongue Tear</b>	140 x 150 lbs./1"	623 x 667 N/2.5 cm	FS 5134 / ASTM 2261
<b>Adhesion</b>	22 lbs./2"	98 N/5 cm	FS 5970 / ASTM D751
<b>Finish</b>	Matte		
<b>Cold Crack</b>	-300F	-340C	FS 5874 / ASTM D2136
<b>Treatments</b>	Anti-Mildew, UV Pigments		
<b>Put-Up</b>	75 yds	69 m	